

HYPOLIMNETIC OXIDATION SYSTEM PERFORMANCE: LAKE THUNDERBIRD 2010-2012

Paul Koenig & Steven Cadenhead
Oklahoma Water Resources Board



DATA SOURCES

Lake Thunderbird Capacity and Water Quality 2001


Developing In-Lake BMPs to Enhance Raw Water
Quality of Oklahoma's Sensitive Water Supply

Lake Thunderbird Water Quality 2012

<http://www.owrb.ok.gov/studies/reports/reports.php>

Lake Thunderbird

- Cleveland County, OK
- 13 miles east of Norman, OK
- Normal Pool Capacity
 - 106,669 ac-ft
- Yield
 - 21,600 ac-ft (Conjunctive)
 - 15,600 ac-ft (Basic)




Lake Thunderbird

Federally Owned Lake,
Constructed in 1965
Jurisdiction of Bureau of
Reclamation

Operated and Maintained
by the Central
Oklahoma Master
Conservancy District

Raw water for Norman
Midwest City and Del
City



Beneficial Use Designation

Primary- Municipal Water Supply

Flood Control


Recreational

Category 5 on the State 303 (d) list:


- Turbidity and Low Dissolved Oxygen Impairments
- Designated Sensitive Water Supply (SWS)
 - 10 ug/L chlorophyll a
 - elevated TOC due to excessive algae

Key Feature

Lake Thunderbird Stratification



2012 Seasonal Stratification



Process Selection

Goal: Treat anoxic condition in the hypolimnion without disrupting the natural stratification

Identified and Evaluated three processes:

- Artificial Circulation
- Depth Selective Flow Routing
- Supersaturated Dissolved Oxygen Injection System

(SDOX by BlueInGreen, LLC)- Selected Option

Process Selection

COMCD and OWRB secured approval and funding from EPA in 2010 under ARRA. EPA approved SDOX as a “Green Project”

Total Loan Amount: \$1,501,285

Interest and principal free

Clean Water State Revolving Fund (CWSRF)


Funded construction, startup and O&M for a two-year period

Selected Process SDOX


2,000 acre-feet of Hypolimnion Targeted

- 480 acres of sediment

SDOX Process Concept



System Layout



Design Parameters

- Recirculation Flow: 1,536 gpm
- Oxygen Delivery: 5,202 lb/day
- Saturation Chamber: 80" dia X 60" high;
150 psig
- 200-hp pump, 480 V
- Liquid Oxygen Tank: 11,000 gallons

Construction



Modifications

April 2011 nozzles stretched further out

- West ~11m deep
- East ~ 12 m deep

Spring 2012 nozzle redesigned

- installed July
- West line shut off (break in line)

Construction




Construction Schedule

- Design Start September 22, 2009
- Design Completed December 1, 2009
- Approval/Bidding February 29, 2010
- Construction March 1, 2010
- Completion August 2010
(Original June 2010)


Operational Performance

- Partial operation in 2010
- Full season operation in 2011 and 2012
- Primary effects:
 - Increase hypolimnetic DO without disrupting metalimnion
 - Increase oxidation-reduction potential
- Secondary effects:
 - Reduce anaerobic mediated nutrient release
 - Reduce dissolved metals
 - Reduce taste & odor reports
 - Reduce cyanotoxins


Dissolved Oxygen



ORP



Temperature






Deepening of 'Mixing Zone'



No SDOX

11' Configuration

Current Configuration



Target area vs. Influenced area




SDOX system attempting to treat 3 times the sediment area, and 6 times the volume than designed.


Data from 8-28-12

LDO Concentration near nozzle : 19mg/l
(300% Saturation)

LDO Concentration is largely above 2mg/L
within “target zone”




LDO Concentration (mg/L)




Phosphorus

2012




Anaerobically Mediated P release peaks mid July....


2009



Nitrogen Data




Historical Chl-*a* Dam Site



SDOX Effects

- ▣ July 2012-system modified
 - New Nozzle
 - Shut off torn west line
- ▣ Data collected suggests modification made significant impact



Performance Summary

The Good

- Modifications reduced mixing, more oxygen to the hypolimnion
- Increased dissolved oxygen & ORP; less dissolved nutrients
- Reduced peak Chl-a, lacustrine chl-a 20% less than 5 year average

The Bad

- Larger zone of influence
- Like 2011, 2012 showed artificial heat transfer to the lake bottom.
- Chl-a still is double the criteria for SWS lakes

Questions?

Thanks to Srini Sundaramoorthy of Tetra Tech and
the Bureau of Reclamation Oklahoma Office